




Product Service

CERTIFICATE

No. Z2 119377 0001 Rev. 00

Holder of Certificate: Xiamen Powerack Solar
Technology Co., Ltd.
307A, No.6 Huli Avenue, Huli District
361006 Xiamen
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Photovoltaic (PV) Mounting System
Model(s): Tile roof mounting system

Parameters:

Construction site:	Germany, the site altitude above sea level is less than 285m.
Snow conditions:	Snow district: Zone 2
Wind zone:	Wind zone 2
Max height of building:	18m
Angle of system:	30°

Tested according to: PPP 59029A:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 6419922318401

Valid until: 2025-05-24

Date, 2023-01-17

(Allen Guo)